

19 May 2023

ShenZhen MOSO Electronics Technology Co., Ltd
No. 1061 Songbai Road Xili
Nanshan District, Shenzhen, Guangdong 518108
CHINA

Attention: Ryan Luo, Dongguan Nore Testing Center Co., Ltd.

CERTIFICATION OF ELECTRICAL EQUIPMENT

It is our pleasure to issue you with the enclosed Certificate of Approval/Conformity EESS-230402-0.

Please immediately check and ensure the details are correct in accordance with your application.

IMPORTANT: This certificate requires the approval markings on the product label to be **CCS- 230402 -EA** and the Regulatory Compliance Mark (**RCM logo**) which must be used in accordance with its conditions of use set out in the latest edition of [AS/NZS 4417.1](#).

EESS Conformity Certification will upload the required certificate information to the National Database as detailed in the Australian/New Zealand Electrical Equipment Safety System (EESS), Equipment Safety Rules Appendix C. The Responsible Supplier must register their equipment of the Certification Equipment Database as part of the EESS and prior to sale.

This certification is based on type testing, modification to the certified product in any way must be notified to EESS Conformity Certification for endorsement. Details of the modification must be advised by completing and submitting the application via our Online Application System (OAS) with your login credentials.


Any change to the name or address of the certificate holder must be notified to EESS Conformity Certification within one calendar month. Changes may be advised by completing and submitting the application via our Online Application System (OAS) with your login credentials.

An application for the transfer of Certificate from the existing Certificate Holder to another/new Certificate Holder may be made to EESS Conformity Certification by completing and submitting the application via our Online Application System (OAS) with your login credentials.

Finally, please use the QR code below to take our two-minute survey and comment on our service.

Should you have any further queries, please contact us.

Yours sincerely,



For and on behalf of
Conformity Certification Services Pty Ltd
trading as EESS Conformity Certification



We'd love to know what you thought of our service. Please scan to fill in a brief survey or visit www.eessconformity.com



Certificate No.: EESS-230402-0

CERTIFICATE OF APPROVAL / CONFORMITY

Certificate Holder: ShenZhen MOSO Electronics Technology Co., Ltd
No. 1061 Songbai Road Xili
Nanshan District, Shenzhen, Guangdong 518108
CHINA

Regulatory Definition: Power Supply or Charger
Product Type: LED Driver (Independent SELV Controlgear Constant Current type)
Risk Level: 3
Trade Name(s): MOSO
Model No(s): X6E-075M056; X6E-075V056; X6E-100M056; X6E-100V056; X6E-150M056;
X6E-150V056; X6E-200M056; X6E-200V056; X6E-240M056; X6E-240V056

Ratings: Input: 100-277V 50/60Hz 0.7-1.6A Class I IP67 Ta 50/55°C, Tc 90°C
Output: 28-56Vdc 240W Max.

Refer to Certificate Addendum for specific ratings

Standard(s): AS 61347.2.13:2018 with AS/NZS 61347.1:2016 +A1:2018
Condition(s): Suitable for outdoor use in Australia, to be installed by licensed electrician for luminaire purposes only.

Required markings: CCS-230402-EA (in accordance with NSW regulatory requirement) **and the**
RCM logo (in compliance with AS/NZS 4417.1 & 2 and the EESS requirement)

Date of Issue: 19 May 2023
Valid until: 18 May 2028

Conformity Certification Services Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies that the Electrical Equipment as described on this certificate complies with the minimum essential safety requirements for which the application has been made. This certificate meets the requirement of the New South Wales Government Recognised External Approvals Scheme (REAS) and Queensland Government Recognised External Certification Scheme (RECS). Certification is based on type testing and within our terms and conditions.

For and on behalf of
Conformity Certification Services Pty Ltd
trading as EESS Conformity Certification



Fair
Trading

Queensland
Government

This certificate is recognised by all other States and Territories of Australia and New Zealand.

Suite 3, 695 The Horsley Drive, Smithfield,
NSW 2164, AUSTRALIA

www.eessconformity.com

The trademarks above remain the property of their respective owners.



www.jas-anz.org/register



Certificate No.: EESS-230402-0

CERTIFICATE ADDENDUM

Model No	Rating Details
X6E-075M056	Input: 100-277V 50/60Hz 0.7A Max. Output Voltage: 28-56Vdc ; Output Current: 0.215-2.15A Output Power: 53-75W Max. Uout Max. 80Vdc
X6E-075V056	Input: 100-277V 50/60Hz 0.7A Max. Output Voltage: 28-56Vdc Output Current: 0.9-2.15A Output Power: 53-75W Max. Uout Max. 80Vdc
X6E-100M056	Input: 100-277V 50/60Hz 0.9A Max. Output Voltage: 28-56Vdc Output Current: 0.285-2.85A Output Power: 70-100W Max. Uout Max. 80Vdc
X6E-100V056	Input: 100-277V 50/60Hz 0.9A Max. Output Voltage: 28-56Vdc Output Current: 1.2-2.85A Output Power: 70-100W Max. Uout Max. 80Vdc
X6E-150M056	Input: 100-277V 50/60Hz 1.3A Max. Output Voltage: 28-56Vdc ; Output Current: 0.43-4.3A Output Power: 105-150W Max. Uout Max. 80Vdc
X6E-150V056	Input: 100-277V 50/60Hz 1.3A Max. Output Voltage: 28-56Vdc Output Current: 1.8-4.3A Output Power: 105-150W Max. Uout Max. 80Vdc
X6E-200M056	Input: 100-277V 50/60Hz 1.6A Max. Output Voltage: 30-56Vdc Output Current: 0.57-5.7A Output Power: 120-200W Max. Uout Max. 70Vdc



Certificate No.: EESS-230402-0

Model No	Rating Details
X6E-200V056	Input: 100-277V 50/60Hz 1.6A Max. Output Voltage: 30-56Vdc Output Current: 2.30-5.7A Output Power: 120-200W Max. Uout Max. 70Vdc
X6E-240M056	Input: 100-277V50/60Hz 1.8A Max. Output Voltage: 30-56Vdc Output Current: 0.685-6.85A Output Power: 144-240W Max. Uout Max. 70Vdc
X6E-240V056	Input: 100-277V 50/60Hz 1.8A Max. Output Voltage: 30-56Vdc Output Current: 2.65-6.85A Output Power: 144-240W Max. Uout Max. 70Vdc

For and on behalf of
Conformity Certification Services Pty Ltd
trading as EESS Conformity Certification